

Questions and Answers - Installation of Water Line from Deep Water Well to U/G Water Tank at Annex Compound

Solicitation # SBG30014Q1235

Dear Prospective Offeror,

Please see answers in response to the questions received from the following contractors on the subject solicitation:

Questions from Zakaria & Associates:

Question 1: Item No. 02 of Bid Schedule i.e 75mm dia HDPE pipe is not available in our country, but the following pipes are locally available.

SI No.	Brand Name	Thickness	Length
01.	BRB	5.63 mm	6 meter
02.	National Polymer	5.5 mm	6 meter
03.	Aziz	5.5 mm	6 meter
04.	PPR	12 mm	3 meter

Answer: if HDPE is not available alternatively they can provide Steel pipe of similar size conforming to AWWA C 200 or standard black steel pipe conforming to ASTM A 53.

Questions from BR Construction

Question 2: Please be informed that under sl. no. 2 of BOQ "75 mm HDPE pipe" are not available in local market.

Answer: if HDPE is not available alternatively they can provide Steel pipe of similar size conforming to AWWA C 200 or standard black steel pipe conforming to ASTM A 53.

Thanks and regards, Shahana Begum

Contracting Specialist
Procurement and Contracting Section
American Embassy, Dhaka, Bangladesh
Tel: 880 2 8855500
Fax: 880 2 8822551